



ಸಂಖ್ಯೆ : ಸ.ಕಾ.ಅ/ಲೋ.ಇ/ಉ.ವಿ/ಮಾಗಡಿ/ಸ.ಇ01/ಎನ್.ಬಿ.ಸಿ/2022-23/350

ದಿನಾಂಕ: 18/08/2022

ರವರಿಗೆ,

ಕಾರ್ಯದರ್ಶಿಗಳು

ವೆಂಕಟ್ ಇಂಟರ್‌ನ್ಯಾಷನಲ್ ಪಬ್ಲಿಕ್ ಸ್ಕೂಲ್

ಜಮಾಲ್ ಸಾಬ್ ಪಾಳ್ಯ,

ಹುಲಿಯೂರುದುರ್ಗ ರಸ್ತೆ,

ಮಾಗಡಿ ತಾಲ್ಲೂಕು.

ಮಾನ್ಯರ,

ವಿಷಯ: ವೆಂಕಟ್ ಇಂಟರ್‌ನ್ಯಾಷನಲ್ ಪಬ್ಲಿಕ್ ಸ್ಕೂಲ್, ಜಮಾಲ್ ಸಾಬ್ ಪಾಳ್ಯ,  
ಹುಲಿಯೂರುದುರ್ಗ ರಸ್ತೆ, ಮಾಗಡಿ ತಾಲ್ಲೂಕು ಕಟ್ಟಡದ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರ  
ನೀಡುವ ಬಗ್ಗೆ.

ಉಲ್ಲೇಖ: 1. ಸರ್ಕಾರದ ಆದೇಶ ಸಂಖ್ಯೆ: ಲೋಇ/59/ಬಿಇಡಿ/2019, ದಿನಾಂಕ: 06-05-2022.  
2. ತಮ್ಮ ಮನವಿ ದಿನಾಂಕ: 06-08-2022.

\* \* \* \* \*

ಮೇಲ್ಕಂಡ ವಿಷಯಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ, ವೆಂಕಟ್ ಇಂಟರ್‌ನ್ಯಾಷನಲ್ ಪಬ್ಲಿಕ್ ಸ್ಕೂಲ್, ಜಮಾಲ್ ಸಾಬ್ ಪಾಳ್ಯ,  
ಹುಲಿಯೂರುದುರ್ಗ ರಸ್ತೆ, ಮಾಗಡಿ ತಾಲ್ಲೂಕು ಇಲ್ಲಿ ನಡೆಸಲು ಉದ್ದೇಶಿಸಿರುವ ಶಾಲಾ ಕಟ್ಟಡಕ್ಕೆ ಶೈಕ್ಷಣಿಕ  
ಉದ್ದೇಶಕ್ಕಾಗಿ ಕಟ್ಟಡದ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರ ನೀಡಲು ಉಲ್ಲೇಖ ಪತ್ರ (2)ರಲ್ಲಿ ಕೋರಿರುತ್ತೀರಿ.


ಅದರಂತೆ ಸದರಿ ಕಟ್ಟಡವನ್ನು ಪರಿಶೀಲಿಸಲಾಗಿ ನೆಲಮಹಡಿ ಮತ್ತು ಮೂರು ಅಂತಸ್ಥಿನ ಕಟ್ಟಡವಿದ್ದು, ಆರ್.ಸಿ.ಸಿ  
ಛಾವಣಿ, ಇಟ್ಟಿಗೆ ಗೋಡೆ, ಗ್ರಾನೈಟ್ ನೆಲಹಾಸು, ಸಿ.ಪಿ.ವಿ.ಸಿ, ಮರ ಮತ್ತು ಗಾಜಿನಿಂದ ಕೂಡಿದ ಕಿಟಕಿಗಳು, ಮರದ  
ಬಾಗಿಲುಗಳು, ನೀರು ಸರಬರಾಜು ನೈರ್ಮಲ್ಯೀಕರಣ ವ್ಯವಸ್ಥೆ ಹಾಗೂ ವಿದ್ಯುತ್ ಸರಬರಾಜು ಹೊಂದಿರುತ್ತದೆ.

ಸದರಿ ಕಟ್ಟಡವನ್ನು Bangalore University, Department of Civil Engineering, UVCE, Jnana Bharathi,  
Bangalore ರವರು ತಪಾಸಣೆ ಮಾಡಿ ರೀಬಾಂಡ್ ಹ್ಯಾಮರ್ ಮತ್ತು ಅಲ್ಯುಮಿನಿಯಂ ಪಲ್ಸ್ ವೆಲಾಸಿಟಿ ಪರೀಕ್ಷೆಗಳನ್ನು  
ಮಾಡಿ ಕಟ್ಟಡ ಸುರಕ್ಷಿತವಾಗಿದೆ ಎಂಬುದರ ಬಗ್ಗೆ ಉಲ್ಲೇಖಿತ ಪತ್ರ (2) ರಲ್ಲಿ ವರದಿಯನ್ನು ಸಲ್ಲಿಸಿದ್ದು, ಸದರಿ  
ಕಟ್ಟಡವನ್ನು 2016ರಲ್ಲಿ ನಿರ್ಮಿಸಿರುವುದಾಗಿ ತಿಳಿಸಿರುತ್ತಾರೆ.

ಅದರಂತೆ ಶಾಲಾ ಕಟ್ಟಡದ ಪರಿವೀಕ್ಷಣೆಯನ್ನು ದಿನಾಂಕ:18-08-2022ರಂದು ಕಟ್ಟಡದ ಮಾಲಿಕರು ಹಾಗೂ  
Sree Tech Supports, Civil Engineering Consultants and Laboratories, Bangalore ರವರೊಂದಿಗೆ ಜಂಟಿಯಾಗಿ  
ತಪಾಸಣೆ ಮಾಡಲಾಗಿರುತ್ತದೆ. ಕಟ್ಟಡಗಳು Structurally stable ಇರುವುದಾಗಿ Sree Tech Supports, Civil  
Engineering Consultants and Laboratories, Bangalore ತಾಂತ್ರಿಕ ತಂಡ ಹಾಗೂ Bangalore University,  
Department of Civil Engineering, UVCE, Jnana Bharathi, Bangalore ರವರು ಸದರಿ ಕಟ್ಟಡಗಳು Structurally stable  
ಇರುವುದಾಗಿ ವರದಿ ನೀಡಿರುವುದನ್ನು ಪರಿಗಣಿಸಿ ಕಟ್ಟಡವು ಮೇಲ್ನೋಟಕ್ಕೆ structurally stable ಆಗಿದ್ದು, ಉಲ್ಲೇಖ  
(1)ರ ಸರ್ಕಾರದ ಆದೇಶದ ಪ್ರಕಾರ ಗ್ರಾಮೀಣ ಪ್ರದೇಶ ವ್ಯಾಪ್ತಿಗೆ ಒಳಪಟ್ಟಿರುವುದರಿಂದ ರೂ.1000/- ಶುಲ್ಕವನ್ನು  
ಪಾವತಿಸಿಕೊಂಡು ಹಾಗೂ ಕಾಲಕಾಲಕ್ಕೆ ಈ ಕೆಳಕಂಡ ಅಂಶಗಳನ್ನು ಅಳವಡಿಸಿಕೊಳ್ಳುವ ಷರತ್ತಿನ ಮೇರೆಗೆ ಸದರಿ  
ಶಾಲಾ ಕಟ್ಟಡಕ್ಕೆ ಎನ್.ಬಿ.ಸಿ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ನೀಡಲಾಗಿದೆ.

1. ಗೋಡೆಗಳಿಗೆ ಕಾಲಕಾಲಕ್ಕೆ ಅವಶ್ಯವಿದ್ದಲ್ಲಿ ಮುಡಿ ಮಾಡುವುದು ಮತ್ತು ಬಣ್ಣ ಬಳಿಯುವುದು.
2. ಭಾವಣಿ ಮೇಲ್ಭಾಗದಲ್ಲಿ ನೀರು ಸೋರದಂತೆ ಹವಾನಿರೋಧಕ ಪದರವನ್ನು ಕಾಲಕಾಲಕ್ಕೆ ಅಳವಡಿಸುವುದು.
3. ಗೋಡೆ ಮತ್ತು ಭಾವಣಿಯ ಮೇಲ್ಭಾಗದಲ್ಲಿ ಉಂಟಾಗುವ ಸಣ್ಣ ಸಣ್ಣ ಬಿರುಕುಗಳನ್ನು ಮುಚ್ಚುವುದು ಮತ್ತು ಕಟ್ಟಡ ನಿರ್ವಹಣೆ ಕಾಮಗಾರಿಗಳನ್ನು ಸಮರ್ಪಕವಾಗಿ ಕೈಗೊಳ್ಳುವುದು.
4. ಪಾರ್ಕಿಂಗ್ ವ್ಯವಸ್ಥೆಯನ್ನು ಕಲ್ಪಿಸುವುದು.
5. ಶಾಚಾಲಯ ಕಟ್ಟಡಕ್ಕೆ ನೀರಿನ ಸೌಲಭ್ಯ ಹಾಗೂ ಸ್ವಚ್ಛತೆಯ ಬಗ್ಗೆ ಕ್ರಮ ವಹಿಸುವುದು.

ತಮ್ಮ ವಿಶ್ವಾಸಿ



ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್

ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ.

ನಂ.4 ಉಪ ವಿಭಾಗ, ಮಾಗಡಿ.

Government of Karnataka  
Office of the Asst. Executive Engineer  
Public Works Department,  
Sub -Division, Magadi-562 120.

---

No.AEE/PWD/S.D/Magad/P.E1/NBC/2022-23/350  
Date : 18-08-2022

To:

The Secretary,  
Venkat International Public School,  
Jamal Sab Palya,  
Huliyurdurga Road,  
Magadi Taluk.

Sir,

Sub :- Providing "Building Safety Certificate"  
for Venkat International Public School,  
Jamal Sab Plya, Huliyurdurga Road,  
Magadi Taluk-reg.

Ref:- 1) Government order No.PWD/59/B.Ed/  
2009 dated 06-05-2022.

2) Your representation dated 06-08-2022.

----

With reference to the above cited subject you  
have requested for issue of " Safety Certificate" under  
your letter at Ref (2) in respect to the school building  
of Venkat International Public School, Jamal Sab Palya,  
Huliyurdurga Road, Magadi Taluk, wherein proposed to  
conduct school.





Accordingly the said building is inspected and it consist ground and three upper floors, RCC roof, constructed with brick wall, granite flooring, C.P.V.C, wood and glass fitted windows, wooden doors water supply, sanitary system also possessed with electricity supply.

Accordingly the school building inspection was conducted on 18-08-2022 jointly with building owner also Sree Tech Supports, Civil Engineering Consultants and Laboratories, Bangalore jointly. The buildings having structural stable and it is reported by Sree Tec Supports. Civil Engineering Consultants and Laboratgories, Bangalore by its technical team also Bangalore University, Department of Civil Engineering, UVCE, Jnana Bharathi, Bangalore who give report about structural stable of the said building and by considering the same at the outlook the building shows structurally stable, as per the Government order vide Ref (1) it comes under the jurisdiction of rural area and hence by collecting fee o f Rs.1000/- also by imposing condition



that the below mentioned points to be adopted from time to time the N.B.C Certificate given to the said school building.

1. Providing duncce to the walls from time to time, if necessary and paint the same.
2. On the terrace portion without leakage of water the air resistance layer to be provided.
3. Small cracks which may arise in the wall and roof to be covered and building maintenance works to be taken up effectively.
4. Provide parking arrangement.
5. Provide water facility to toilet also to maintain cleanliness and for which to take action.

Yours faithfully,


Sd/-

Asst. Executive Engineer  
Public Works Department  
No.1, Sub Division, Magadi.

// True copy //

Kannada to English Translated by

**ATTESTED BY ME**



ಕಲ್ಪನ.ಬಿ.ಎ.  
ಹಳೇ ಕನ್ನಡದಿಂದ ಹೊಸ ಕನ್ನಡಕ್ಕೆ  
ಬರಳಿ ಮಾರ್ಪಡಿಸಿದ್ದೇನೆ.  
ಸಿಟಿ ಸಿವಿಲ್ ಕೋರ್ಟ್ ಆಫೀಸರ್,  
ಬೆಂಗಳೂರು-560009  
ಮೊ : 9945884353

B. HANUMANTHARAYA, B.A., LL.B.,  
ADVOCATE & NOTARY  
# 13/1, 4th 'A' Cross, K.N. Extension  
Yeshwanthpura, Bengaluru - 560 022.